

		"AS MANUFACTURING" LLC S. Sklyarenka Str., 5, Kyiv, 04073, Ukraine Registered in Ukraine: 42593133
---	---	---

DECLARATION OF PERFORMANCE
 According to Construction Products Regulation EU No 305/2011
 No 1922-CPR-2368
 (issue 2)

1. Unique identification code of the product-type:

Model: name EN54 FireProtect (Smoke) Jeweller, model FP.54S.J-000-EU

Brand: AJAX

2. Intended use/es:

Fire detection and fire alarm systems. Smoke detectors - Point detectors using scattered light, transmitted light or ionization. Components using radio links.

3. Manufacturer:

"AS MANUFACTURING" LLC, S. Sklyarenka Str., 5, Kyiv, 04073, Ukraine

4. System(s) of AVCP:

System 1.

5. Harmonised standard/s:

EN 54-7:2018, EN 54-25:2008, EN 54-25:2008/AC:2012.

Notified body:

1922 DEDAL, Attestation & Certification

6. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
EN 54-7:2018		
Operational reliability	Pass	4.2.1, 4.2.3, 4.2.4, 4.2.6, 4.2.7, 4.2.8
	N/A	4.2.2, 4.2.5
Nominal activation conditions / Sensitivity	Pass	4.3.1, 4.3.2, 4.3.3
Response delay (response time)	Pass	4.4.1, 4.4.2
Tolerance to supply voltage	Pass	4.5
Performance parameters under fire conditions	Pass	4.6
Durability of Nominal activation condition/ Sensitivity	Pass	4.7.1.1, 4.7.1.2
Humidity resistance	Pass	4.7.2.1, 4.7.2.2
Corrosion resistance	Pass	4.7.3
Vibration resistance	Pass	4.7.4.1, 4.7.4.2, 4.7.4.3, 4.7.4.4
Electrical stability	Pass	4.7.5

EN 54-25:2008, EN 54-25:2008/AC:2012		
Performance under fire conditions	Pass	4.1, 4.2.2, 5.2, 8.3.7
Response delay (response time to fire)	Pass	8.2.3, 8.2.6
Operational reliability	Pass	4.2.1, 4.2.3, 4.2.4, 4.2.5, 4.2.6, 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.6
	N/A	8.3.5
Durability of operational reliability and response delay, temperature resistance	Pass	8.3.9, 8.3.10, 8.3.11
Durability of operational reliability, vibration resistance	Pass	8.3.16, 8.3.17, 8.3.18, 8.3.19
Durability of operational reliability, humidity resistance	Pass	8.3.13, 8.3.14
	N/A	8.3.12
Durability of operational reliability, corrosion resistance	Pass	8.3.15
Durability of operational reliability, electrical stability	Pass	8.3.20

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.


Signed for and on behalf of the manufacturer by:

Serhii Ivchun

Name

Kyiv, Ukraine, March 17th 2025

Attorney by virtue of the PoA





"AS MANUFACTURING" LLC
S. Sklyarenka Str., 5, Kyiv, 04073, Ukraina
Beregszámítva Ukrajnában: 42593133

TELJESÍTMÉNY NYILATKOZAT
Az EU Építőipari Termékek Szabályozása 305/2011 számú rendelete szerint
Nem 1922-CPR-2368
(2. kiadás)

1. A terméktípus egyedi azonosítószáma: Modell: az EN54 FireProtect (Smoke) Jeweller, modell FP.54S.J-000-EU
Márka: AJAX
2. Tervezett felhasználás: Tűzérzékelő és tűzjelző rendszerek. Füstérzékelők - Pontszerű érzékelők, amelyek szórt fényt, továbbított fényt vagy ionizációt használnak. Összetevők, amelyek rádiókapcsolatot használnak.
3. Gyártó: "AS MANUFACTURING" LLC, S. Sklyarenka Str., 5, Kyiv, 04073, Ukraina
4. AVCP rendszer: Rendszer 1
5. Harmonizált szabványok: EN 54-7:2018
EN 54-25:2008
EN 54-25:2008/AC:2012
Notified body: 1922 DEDAL, Attestation & Certification

6. Nyilatkozott teljesítmény:

Alapvető jellemzők	Teljesítmény	Harmonizált műszaki specifikáció
EN 54-7:2018		
Működési megbízhatóság	Átad	4.2.1, 4.2.3, 4.2.4, 4.2.6, 4.2.7, 4.2.8
	N/A	4.2.2, 4.2.5
Nominális aktiválási feltételek / Érzékenység	Átad	4.3.1, 4.3.2, 4.3.3
Válasz késleltetés (válaszidő)	Átad	4.4.1, 4.4.2
Tűréshatár az tápfeszültségre	Átad	4.5
Teljesítmény paraméterek tűz esetén	Átad	4.6
Tartósság a nominális aktiválási feltételek/ Érzékenység	Átad	4.7.1.1, 4.7.1.2
Páratartalom-ellenállás	Átad	4.7.2.1, 4.7.2.2
Korrózió-ellenállás	Átad	4.7.3
Zaj-ellenállás	Átad	4.7.4.1, 4.7.4.2, 4.7.4.3, 4.7.4.4
Elektromos stabilitás	Átad	4.7.5

EN 54-25:2008, EN 54-25:2008/AC:2012		
Teljesítmény tűz esetén	Átad	4.1, 4.2.2, 5.2, 8.3.7
Válasz késleltetés (válaszidő tűz esetén)	Átad	8.2.3, 8.2.6
Működési megbízhatóság	Átad	4.2.1, 4.2.3, 4.2.4, 4.2.5, 4.2.6, 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.6
	N/A	8.3.5
Működési megbízhatóság és válasz késleltetés tartóssága, hőmérséklet-ellenállás	Átad	8.3.9, 8.3.10, 8.3.11
Működési megbízhatóság tartóssága, rezgésállóság	Átad	8.3.16, 8.3.17, 8.3.18, 8.3.19
Működési megbízhatóság tartóssága, páratartalom-ellenállás	Átad	8.3.13, 8.3.14
	N/A	8.3.12
Működési megbízhatóság tartóssága, korrózióállóság	Átad	8.3.15
Működési megbízhatóság tartóssága, elektromos stabilitás	Átad	8.3.20

A fenti azonosított termék teljesítménye összhangban áll a megadott teljesítményekkel. Ezt a teljesítménynyilatkozatot a 305/2011/EK rendelet alapján, a fenti gyártó kizárólagos felelőssége alatt adjuk ki.

Aláírva a gyártó nevében:

Hely Kijev, Ukrajna	Név Serhii Ivchun Funkció Ügyvéd a PoA alapján	Ellenőrizze az aláírást a mellékelt származásnyilatkozaton Dátum 2025. március 7.
-------------------------------	---	--